



**NASSAU COUNTY  
DEPARTMENT OF HEALTH**  
106 CHARLES LINDBERGH BLVD.  
UNIONDALE, NEW YORK 11553  
PHONE: 516-227-9538  
FAX: 516-227-9611

October 7, 2013

Mr. Russell Ford, P.E.  
AGVIO/CH2M HILL  
119 Cherry Hill Road, Suite 300  
Parsippany, New Jersey 07052


Re: Request for a Waiver of Article XI  
Regulations, Section 13.2.4(i)  
Nassau County Public Health Ordinance  
Tank to Water Line Separation Distance  
New York American Water - Plant  
670 Seamans Neck Road  
Levittown, New York 11756  
NCHD Facility ID #1483

Dear Mr. Ford:

We have reviewed and herein approve your request dated September 26, 2013 for a waiver of Section 13.2.4(i) of the Article XI Regulations of the Nassau County Public Health Ordinance which requires a ten (10) foot separation between water lines and product storage tanks and product piping. This waiver is granted to allow for a separation distance of 5', 5" between the 16" underground water main and the three (3) 165 gallon aboveground sodium hypochlorite tanks located in a concrete dike inside the treatment building due to the physical constraints imposed by the utilities at the site. The tank installations must comply with all other requirements of Article XI and its Regulations.

If you have any questions, please call Robert Weitzman, P.E at (516) 227-9538.

Very truly yours,

  
Donald P. Irwin, Director  
Environmental Health Programs

DPI:RW:jw

cc: New York American Water (Merrick) – William Varley, Richard Kern, P.E.  
NAVFAC – Lora Fly, Commander  
Tetra Tech, Inc. – David Brayack, P.E.  
Town of Hempstead Building Department - Brian Nocella, Inspector  
NCHD - Michael J. Alarcon, P.E., Patricia Ramirez, P.E.